

CENTRALISED VENTILATION SYSTEM FOR PREVENTING NOSOCOMIAL TRANSMISSION OF TUBERCULOSIS IN A HOSPITAL ISOLATION WARD

MD RAJUNA BIN AHMAD SHAKRI

UNIVERSITI TEKNOLOGI MALAYSIA

CENTRALISED VENTILATION SYSTEM FOR PREVENTING NOSOCOMIAL
TRANSMISSION OF TUBERCULOSIS IN A HOSPITAL ISOLATION WARD

MD RAJUNA BIN AHMAD SHAKRI

A dissertation submitted in partial fulfilment of the
requirements for the award of the degree of
Doctor of Engineering (Technology and Construction Management)

Faculty of Civil Engineering
Universiti Teknologi Malaysia

JULY 2016

To my beloved mother and father

Hajah Sarifah Binti Naim

Almarhum Haji Ahmad Shakri Bin Mohd Sekak

To my beloved wife and kids

Nor Hidayati Binti Suhadi

Muhammad Harist Danish Bin Md Rajuna

Dewi Sarah Binti Md Rajuna

Muhammad Hadi Darwish Bin Md Rajuna

Muhammad Hazim Daim Bin Md Rajuna

To my beloved mother and father in law

Hajah Ruminah Binti Dollah Anuar

Almarhum Suhadi Bin Abdul Karim

To my beloved younger sisters and brother

Dewi Rohani Binti Ahmad Shakri

Dewi Sukmawati Binti Ahmad Shakri

Dewi Murni Binti Ahmad Shakri

Saiful Wahyullah Bin Ahmad Shakri

Thanks for the support and encouragement given.

ACKNOWLEDGEMENT

In preparing this thesis, I was in contact with many people, researchers, academicians and practitioners who have contributed towards my understanding and thoughts. In particular, I wish to express my sincere appreciation to my supervisors, Associate Professor Dr. Rozana Binti Zakaria and Dr. Khairulzan Bin Yahya for their encouragement, guidance, critique, friendship, advice and motivation. Without their continued support and interest, this thesis would not have been the same as presented here.

This study was registered by Ministry of Health Malaysia (MoH) under Institute for Medical Research (IMR) and National Institutes of Health Malaysia with registration approval code of NMRR-10-68-5182. Special thanks to the director of Johor State Health Department (JSHD), Dr Khairi Bin Yakob; the epidemiologist, Dr Badrul Hisham Bin Abd Samad and all members of Public Health Division, JSHD who have been very helpful and encouraging. In addition, I would like to thank all the staffs in the respiratory medical department and TB Isolation Ward in the Sultanah Aminah Hospital Johor Bahru. Special thanks to the Head of Department and consultant, Dr Noor Aliza Bt Md Tarekh and the Director of Hospital Sultanah Aminah Johor Bahru, Dr Daud Bin Abdul Rahim who I owe much gratitude for the authorization to carry out the study in the above mentioned field.

My fellow postgraduate students should also be recognized for their aids. My sincere thanks also extend to all my colleagues and others who have provided assistance at various occasions. Their views and tips were very useful indeed. Besides, I would like to express my sincere thanks to all the parties who have been directly and indirectly involved in this study. Last but not least, my sincere appreciation also extends to all my family members for their support and encouragement.

ABSTRACT

Centralised ventilation increases indoor air quality for a healthy hospital indoor environment by supplying fresh air from outside to inside the isolation ward and dispose out the stale air. Poor ventilation for isolation wards can increase risks of nosocomial transmission. Thus, the aim of the study is to develop a healthcare setting layout in healthy indoor air environment in order to prevent the nosocomial transmission of Tuberculosis (TB) by centralised mechanical ventilation system for TB isolation ward. This study was conducted at Hospital Sultanah Aminah, Johor Bahru and four stages of qualitative and quantitative research methods were involved. The first step was the interview and questionnaire stage with Healthcare Workers (HCWs) at TB Isolation Wards and Respiratory Specialist Clinic. The second stage was to determine the existing TB isolation ward. The third step was mapping rooms' temperature with imaging thermal infrared. Finally, the design and installation of a mock up room with a centralised ventilation system was evaluated. Thirty nine HCWs answered the five Likert Scale questionnaire survey which identified indoor air environment sustainability factors. Four factors have been selected to choose the most effective room as a mock up. Based on findings, single bedroom was the most effective one based on calculation of air density per patient. The mock up design for selected isolation ward SB2 is 3.000 m length x 2.000 m width x 3.144 m height. Room temperature changes were detected using temperature mapping when the windows set to close and open. A mock up room manages the route of airborne TB transmission and has been designed and installed centralised ventilation system for three persons (1 patient and 2 HCWs) in one time, 15.7 Air Change per Hour (ACH) more than 12 ACH specification requirement, whereby the performance ventilation indicator carbon dioxide does not exceed 1,000 ppm in one time. However, relative humidity and temperature exceeded their acceptable range depending on the surrounding environmental conditions. The study is concerned about the HCWs to protect them by preventing nosocomial TB transmission. The mock up of innovations designed based on environmental and engineering controls has been shown to help in eliminating Building Related Illnesses (BRIs). Thus, it is suggested that this mock up is recommended to function its role not only in Hospital Sultanah Aminah but also in other hospitals.

ABSTRAK

Pengudaraan berpusat meningkatkan kualiti udara dalaman untuk persekitaran dalaman hospital yang sihat dengan membekalkan udara segar dari luar ke dalam wad isolasi dan melupuskan keluar udara yang tidak sihat. Pengudaraan yang kotor bagi wad pengasingan boleh meningkatkan risiko jangkitan yang berlaku di hospital. Oleh itu, tujuan kajian ini adalah untuk membangunkan susun atur penjagaan kesihatan di persekitaran udara dalaman yang sihat untuk mengelakkan jangkitan Batuk Kering (TB) yang diperolehi di hospital dengan sistem pengudaraan mekanikal berpusat bagi wad pengasingan TB. Kajian ini telah dijalankan di Hospital Sultanah Aminah, Johor Bahru dan empat peringkat kaedah penyelidikan kualitatif dan kuantitatif yang terlibat. Langkah pertama adalah peringkat temuduga dan soalselidik dengan pekerja penjagaan kesihatan (HCWs) di Ward Pengasingan TB dan Klinik Pakar Pernafasan. Langkah kedua adalah menentukan wad pengasingan TB yang sedia ada. Langkah ketiga adalah pemetaan suhu bilik dengan pengimejan suhu inframerah. Akhir sekali, telah menilai rekabentuk bilik wad contoh dan pemasangan sistem pengudaraan berpusat. Tiga puluh sembilan HCWs telah menjawab lima *Likert Scale* dalam kajian soalselidik bagi mengenal pasti faktor-faktor kemampuan persekitaran udara dalaman. Empat faktor telah dipilih untuk memilih bilik yang paling berkesan sebagai wad contoh. Berdasarkan penemuan, bilik katil seorang adalah yang paling berkesan berdasarkan pengiraan ketumpatan udara setiap pesakit. Bilik SB2 wad pengasingan TB direkabentuk untuk wad contoh telah dipilih adalah 3.000 m panjang x 2.000 m lebar x 3.144 m tinggi. Perubahan suhu bilik dikesan menggunakan pemetaan suhu apabila tingkap ditetapkan ditutup dan dibuka. Bilik wad contoh menguruskan laluan jangkitan TB bawaan udara telah direkabentuk dan dipasang sistem pengudaraan berpusat untuk tiga orang (1 pesakit dan 2 HCWs) dalam satu masa, 15.7 kadar pertukaran udara sejam (ACH) melebihi 12 ACH keperluan spesifikasi, di mana penunjuk prestasi pengudaraan karbon dioksida tidak melebihi 1,000 ppm dalam satu masa. Walau bagaimanapun, kelembapan relative dan suhu melebihi julat yang boleh diterima kerana ianya bergantung kepada keadaan alam sekitar di sekeliling. Kajian ini mengambil berat tentang HCWs untuk melindungi mereka dari jangkitan TB yang diperolehi di hospital. Inovasi bilik wad contoh yang direkabentuk ini berasaskan kawalan alam sekitar dan kejuruteraan telah dibuktikan boleh membantu menghapuskan Bangunan Berkaitan Penyakit (BRIs). Oleh itu, dicadangkan wad contoh ini untuk berfungsi peranannya bukan sahaja di Hospital Sultanah Aminah tetapi juga disyorkan di hospital-hospital lain.

TABLE OF CONTENTS

CHAPTER	TITLE	PAGE
	DECLARATION	ii
	DEDICATION	iii
	ACKNOWLEDGEMENT	iv
	ABSTRACT	v
	ABSTRAK	vi
	TABLE OF CONTENTS	vii
	LIST OF TABLES	xi
	LIST OF FIGURES	xiii
	LIST OF ABBREVIATIONS	xvii
	LIST OF SYMBOLS	xviii
	LIST OF APPENDICES	xix
1	INTRODUCTION	1
	1.1 Background of the Study	1
	1.2 Statement of the Problem	2
	1.3 Aim of Study	4
	1.4 Objectives of Study	4
	1.5 Scope of Study	4
	1.6 Significance of the Study	5
	1.7 Novelty Study	6
	1.8 Summary of Introduction	7
2	LITERATURE REVIEW	8
	2.1 Introduction	8
	2.2 History of Tuberculosis	9

2.3	Case in Malaysia	11
2.4	Tuberculosis	13
2.4.1	<i>Mycobacterium tuberculosis</i>	14
2.4.2	Transmission of Tuberculosis	15
2.5	Hierarchy of TB Infection Controls	16
2.5.1	Administrative Controls	17
2.5.2	Environmental and Engineering Controls	17
2.5.3	Respiratory Protection Controls	18
2.6	Air	18
2.6.1	Survival of Pathogens in the Air	19
2.7	Isolation Ward	22
2.7.1	Pressurization	24
2.7.2	Ventilation	25
2.7.3	Dilution of Air	30
2.7.4	Airflow	33
2.7.4.1	Direction of Airflow	35
2.7.5	Air Exchange Rates	36
2.7.6	Humidity	36
2.7.7	Temperature	37
2.8	Tuberculosis Infection Control	38
2.9	Placement and Transportation of Tuberculosis Patients	40
2.10	The Relationship between the Disease and Tuberculosis Isolation Rooms	41
2.11	Factors for Protection and Control of Tuberculosis Transmission at Hospital	43
2.12	Summary of Literature Review	43
3	METHODOLOGY	45
3.1	Introduction	45
3.2	Case Study Selection	47
3.3	Questionnaires and Analysis Development	49
3.3.1	Data Collection	49

3.3.2	Questionnaires	49
3.3.2.1	Method of Questionnaire Collection	50
3.3.2.2	Questionnaires Development	51
3.3.3	Data Analysis and Interpretation	53
3.3.3.1	Mean Index (μ) Analysis	54
3.4	Measuring the Parameters of Existing Building	55
3.5	Ventilation in TB Isolation Ward	56
3.5.1	Carbon Dioxide	59
3.5.2	Relative Humidity	59
3.5.3	Temperature	59
3.5.4	Airflow	60
3.5	Design of Mechanical Ventilation System (Mock up) for TB Isolation Ward	61
3.6	Install Mechanical Ventilation System (Mock up) for TB Isolation Ward	65
3.7	Summary of Methodology	72
4	ANALYSIS, RESULTS AND DISCUSSION OF FINDINGS	73
4.1	Introduction	73
4.2	Factor that Affect the Route of Airborne Tuberculosis Transmission in Indoor Environment	75
4.3	The Relationship between Healthcare Setting Layout and Route Airborne Tuberculosis Transmission	79
4.4	Selected Layout Isolation Room for Mock up Study	83
4.5	Mapping Temperature Healthcare Setting Layout	84
4.6	Centralised Ventilation System for Tuberculosis Isolation Ward	87
4.7	Ventilation Calculation	88
4.8	Ventilation Performance Indicator	90
4.9	Relative Humidity	94
4.10	Room Temperature	97
4.11	Summary Discussion of Findings	101

5	CONCLUSIONS AND RECOMMENDATIONS	102
5.1	Introduction	102
5.2	Conclusions	102
5.3	Recommendations	105
	REFERENCES	108
	Appendices A-D	114-130

LIST OF TABLES

TABLE NO.	TITLE	PAGE
2.1	Disease Names Related to Different Clinical Forms of TB	9
2.2	Hierarchy of Infection Controls	16
2.3	Functional Classification of Isolation Rooms	23
2.4	Recommended Isolation Room Pressures	23
2.5	Checklist of Isolation Rooms	23
3.1	Ranking Criteria (using Likert Method Scale)	52
3.2	Agreement and Mean Index (μ) of Agreement Respondents	54
3.3	Dimensions of Room	56
3.4	Matrix and Label for Blowers (Supply), Exhaust (Return) and Windows	57
4.1	Gander and Service Category Crosstabulation Count	74
4.2	Descriptive Statistics Source of Tuberculosis	76
4.3	Descriptive Statistics High Person Infected Tuberculosis	77
4.4	Descriptive Statistics Medium of Transmission Lead to Infection of Tuberculosis	78
4.5	Descriptive Statistics Indoor Air Environment Sustainability Factors	80
4.6	Descriptive Statistics Type of Preference for Ventilation System	81
4.7	Descriptive Statistics Type Protection and Disinfection System	83
4.8	Rank Effective Size Room Base on Area and Volume Ratio Patient.	84

4.9	Recommendation Load Volume of Airflow and Ventilation Calculations	89
4.10	Statistic Ventilation Performance Indicator	92
4.11	Statistic Relative Humidity %	95
4.12	Statistic Temperature Room °C	98

LIST OF FIGURES

FIGURE NO	TITLE	PAGE
2.1	Estimated TB Incidence Rate in 2013	8
2.2	Symptoms of Different Variants and Stages of Tuberculosis (Häggström, 2009)	13
2.3	Under a high magnification of 15549x (a) colorized scanning electron micrographs (b) bacterium ranges in length between 2 to 4 microns, and a width between 0.2 to 0.5 microns	14
2.4	Transmission of <i>Mycobacterium Tuberculosis</i>	16
2.5	(a) Sneezing can produce as many as 40 000 droplets of 0.5-12 μm . These particles can be expelled at a velocity of 100 m/s, reaching distances of several metres. (b) Smoke visualization of exhalation flow from nose of the right mannequin penetrating into the breathing zone of the left mannequin.	22
2.6	Isolation Ward Layout	24
3.1	Detailed Flowchart of Study Methodology	46
3.2	Location and Picture of Respiratory Clinic (A) and TB Isolation Ward (B), Hospital Sultanah Aminah Johor Bahru, Johor, Malaysia.	48
3.3	Picture (a) and (b) Inside Respiratory Clinic, consultation treatment room sharing medical specialist officer. Picture (c) Inside isolation ward with sharing patient TB in Isolation Ward, Hospital Sultanah Aminah.	48
3.4	Layout Plan and Isometric View TB Isolation Ward at Hospital Sultanah Aminah, Johor Bahru, Johor, Malaysia	51

3.5	Flowchart Measuring Ventilation Mock up Isolation Ward	58
3.6	(a) Velocicalc Meter TSI 6565 (b) Thermal Imaging Cameras FLIR P640 (c) Room Temperature Scale (d) TES 1370 CO ₂ , Temperature and Relative Humidity Meter	60
3.7	View Plan and Layout Plan of Existing TB Isolation Ward	63
3.8	Existing outside view of TB isolation ward with normal open windows: (a) Left view in existing normal condition (c) Middle view and (b) Right view existing normal condition	63
3.9	View Plan and Isometric Design Mock up of TB Isolation Room	64
3.10	Instalation Guide for Blower and Exhaust System	66
3.11	Mechanical Ventilation System	67
3.12	Dimensions for Blower and Exhaust System	68
3.13	Wiring Diagram, Maintanace Instruction and Specifications Guide for Blower and Exhaust System	69
3.14	Layout Mock up Design for Selected Isolation Ward	70
3.15	Mock up Design and Diagram for Selected Existing Isolation Ward SB2	70
3.16	Outside view with installed mechanical ventilation view of TB isolation ward: (a) Picture outside view building TB isoltion ward. (b) Picture outside ceiling view intake fresh air (c) Picture outsite wall view exhaust and (d) Picture ducting at ceiling level.	71
3.17	Inside view of TB isolation room (a) Inside ceiling view of supply fresh air intake and (b) Inside wall view of exhaust	71
4.1	Proportion of the Categories of Job Service HCWs Respondents	74
4.2	Source of Tuberculosis by Respondents	76

4.3	High Risk Person who are Infected by TB	77
4.4	Indoor Environment Medium Transmission of TB by Respondents	78
4.5	Indoor Air Environment Sustainability (IES) Factors	80
4.6	Type of Preference for Ventilation System	82
4.7	Type of Protection and Air Disinfection System	84
4.8	Room Temperature Mapping with all Windows Opened used Thermal Infrared Image FLIR P640	83
4.9	Room Temperature Mapping with all Windows Closed used Thermal Infrared Image FLIR P640	85
4.10	Material Cost and Installation	87
4.11	Result and Analalysis Performance Air Change	89
4.12	Picture installed mock up centerlised ventilation and result with (a) Blower fresh air from outside to inside (No. 1 and No. 2), (b) Exhaust suction pollutant air from inside isolation ward through HEPA filter (No. 3 and No. 4)	90
4.13	Standard Normal Distribution for Frequency Concentration ppm Carbon Dioxide (CO ₂) Level	93
4.14	Density concentration Carbon Dioxide (CO ₂) in ppm before all windows open or close, after during blower no.1, 2 or exhaust no. 3, 4 opened or closed	93
4.15	Ventilation Performance Indicator : Mean density concentration Carbon Dioxide (CO ₂) in ppm before all windows open or close, after during blower no.1, 2 or exhaust no. 3, 4 opened or closed	94
4.16	Standard Normal Distribution for Frequency in Percentage Relative Humidity	96
4.17	Percentage relative humidity during blower no.1, 2 or exhaust no. 3, 4 opened or closed	96
4.18	Mean percentage relative humidity before all windows open or close, after during blower no.1, 2 or exhaust no. 3, 4 opened or closed	97

4.19	Standard Normal Distribution for Frequency Room Temperature °C	99
4.20	Room temperature °C during blower no.1, 2 or exhaust no. 3, 4 opened or closed	99
4.21	Mean room temperature °C before all windows open or close, after during blower no.1, 2 or exhaust no. 3, 4 opened or closed	100

LIST OF ABBREVIATIONS

AII	-	Airborne Infection Isolation
AIIR	-	Airborne infection isolation room
BRI		Building-Related Illness
CDC	-	Centers for Disease Control and Prevention
FDA	-	Food and Drug Administration
HAI	-	Healthcare-associated infections
HEPA	-	High efficiency particulate air [filtration]
HICPAC	-	Healthcare Infection Control Practices Advisory Committee
HIV	-	Human immunodeficiency virus
HCW	-	Healthcare worker
HCWS	-	Healthcare Workers
MDRO	-	Multidrug-resistant organism
MDR-GNB	-	Multidrug-resistant gram-negative bacilli
MTB	-	<i>Bacterium Mycobacterium Tuberculosis</i>
NIOSH	-	National Institute for Occupational Safety and Health, CDC
NNIS	-	National Nosocomial Infection Surveillance
OSHA	-	Occupational Safety and Health Administration
PPE	-	Personal Protective Equipment
PTB	-	Pulmonary Tuberculosis
PV		Personalized Ventilation
SBS		Sick Building Syndrome
TB	-	Tuberculosis
UVGI	-	Ultraviolet Germicidal Irradiation
WHO	-	World Health Organization

LIST OF SYMBOLS

ACH	-	Air Change rate per Hour
q	-	fresh air flow through the room
Q	-	the volumetric flow rate
Q_e	-	the volumetric flow rate of exhaust air
Q_s	-	the volumetric flow rate of supply air
V	-	volume of the room
cfm	-	cubic feet per minute

LIST OF APPENDICES

APPENDIX	TITLE	PAGE
A	Approval Letters from Ministry of Health	114
B	Questionnaires	117
C	Questionnaires Survey Result	121
D	List of Publications	129

CHAPTER 1

INTRODUCTION

1.1 Background of the Study

About one out of three people worldwide is infected by tuberculosis (TB). In 2008, an estimated number of 9.4 million new cases of TB per year which is equivalent to 139 cases per population of 100 000 globally leads to 2 million deaths per year (World Health Organization, 2013). Most cases of active TB occur in regions of Africa (55%) and Asia (30%), with a small proportions of cases in other regions. Treatment for TB takes at least 6 months in forms of medication while strict adherence to treatment is essential to achieve a cure (Md Rajuna *et. al.*, 2011; Md Rajuna *et. al.*, 2012; World Health Organization, 2013).

One of the factors that causes the spread of infection is incomplete treatment and thus resulting in increment of TB cases. At this time, TB is a major cause of morbidity and mortality (Ministry of Health Malaysia, 2014). As reported by Ministry of Health Malaysia, it states that the tuberculosis communicable disease incidence rate and mortality rate per population of 100 000 are 78.28 and 5.37 respectively (Ministry of Health Malaysia, 2014).

Besides, TB can also infect people at the work place such as hospitals. Individuals with close contact to the TB patients are at high risk for acquiring TB infection or nosocomial infections especially Healthcare workers (HCWs). Nosocomial infection is an infection that is acquired during the course of stay in a hospital, nursing home, or other healthcare facilities. Besides, those people who are

working in a hospital also have a high risk of exposure to the suspended TB in the air space that is shared with other active TB patients (Centers for Disease Control and Prevention, 2009).

Nosocomial infections are transmitted in seven ways by Healthcare Infection Control Practices Advisory Committee (HICPAC), Centers for Disease Control and Prevention as follows: (i) direct transmission via person-to-person contact; (ii) indirect transmission when a patient touches an infected surface or receives treatment with improperly sterilized equipment; (iii) droplet transmission via sneezing and coughing; (iv) airborne transmission relies on air movement to spread microorganisms; (v) common vehicle transmission results from food or water; (vi) vector borne transmission via insect or animal and (vii) the longer a patient is hospitalized and the more severe his condition, the higher the risk of nosocomial infection. (Centers for Disease Control and Prevention 2003; World Health Organization, 2004; Centers for Disease Control and Prevention 2005)

A healthy indoor air environment is essential to provide a healthy work place to HCWs who are involved directly with TB patients. The nosocomial infections need to be prevented by improving the indoor air quality as well as the room setting. Thus, the study of healthcare setting layout in healthy indoor air environment needs to be carried out in order to prevent the nosocomial transmission of TB.

1.2 Statement of the Problem

Tuberculosis is an airborne disease that is caused by long rod-shaped bacteria called *Mycobacterium tuberculosis* (MTB). MTB can survive in the human body without showing any sign and symptom. Airborne transmission occurs when bacteria or viruses travel on dust particles or on small respiratory droplets that may become aerosolized when people sneeze, cough, laugh, or exhale. Airborne can travel on air currents over considerable distances. These droplets are loaded with infectious particles.

TB patients may spread the MTB to the people who they spend time with every day. Those who have been treated with correct drugs for at least 2 weeks, however, are no longer contagious (ATS/CDC 2003). Unlike most infections treated with antibiotics, TB treatment requires at least six months to one year to eliminate MTB organism effectively. An unfinished course of chemotherapy not only leaves the patient still sick and still contagious, but also favours the selection of resistant bacteria resulting in MTB strains with multiple drug resistance. Hence, it is very important for TB patients to comply and complete the full course of antibiotic treatment. Failure to do so will result in recurrent infections as well as multi-drug-resistant tuberculosis (MDR-TB) infection that is harder to treat.

All these indoor environmental quality components come together in an ideal situation to produce an indoor environment that satisfies all occupants and would not increase the risk or severity of the illness. The TB colony transmission is hypothetically associated with multiple regressions and area setting such as opening of windows or doors, placement of windows or doors to allow through-flow of air, ceiling height, floor area and wind speed can be used as a control measure of TB transmission (Md Rajuna *et al.*, 2011; Md Rajuna *et al.*, 2012; Escombe *et al.*, 2007).

Room setting which is part of a hospital building is also crucial to provide better indoor environment. Room setting takes into account the room facilities, room layout, location of room, interior finishing, air circulation system and accessibility for maintenance purposes that are vital to the design concepts of a room. The relationship between indoor environmental quality and room setting is important especially for the TB Ward.

Thus, healthcare setting layout in healthy indoor air environment should be developed in order to prevent the nosocomial transmission of TB by centralised ventilation system for TB isolation ward.

1.3 Aim of Study

The Aim of the study is to develop healthcare setting layout in healthy indoor air environment in order to prevent the nosocomial transmission of TB by centralised mechanical ventilation system for TB isolation ward.

1.4 Objectives of Study

The objectives of the study are:

- (i) To identify the factors affecting the TB airborne transmission in hospital indoor environment;
- (ii) To determine the existing TB isolation ward and its layout for mock up study;
- (iii) To determine the relationship between isolation ward setting layout and route airborne TB transmission; and
- (iv) To propose the design of mechanical ventilation system for TB isolation ward in order to reduce nosocomial transmission by route airborne.

1.5 Scope of Study

The study is conducted in the room of number 2 TB isolation ward, Block PP2, Hospital Sultanah Aminah Johor Bahru (HSAJB), Johor, Malaysia. This selected venue is an unconfined TB isolation ward that is not mixed-use with other airborne disease treatment. Figure 3.2 in Chapter 3 shows the location of selected TB isolation ward and respiratory clinic. The selected respondents for questionnaire categories are healthcare workers who are related to TB isolation ward in HSAJB.

The route of direct, droplet and airborne transmission for nosocomial infections in TB isolation ward is studied and conducted in an unconfined situation which is without air conditioning. The comfort parameters which are temperature

(°C), airflow and relative humidity (RH%). Carbon dioxide (CO₂) are in-situ measurement for ventilation performance indicator.

One room in TB isolation ward has been designed and installed with a mechanical ventilation system for the purpose of providing a healthy indoor air environment to prevent nosocomial transmission of TB.

In this study, the limitations are as follows:

- (i) The condition in confined room with no airconditioning and fan switched on.
- (ii) Indoor Environment quality parameters for the test in-situ sampling are temperature, humidity and carbon dioxide.
- (iii) This study does not make disinfecting bacteria MTB.
- (iv) Only one Mock up room with a single bed made with mechanical ventilation system is selected in the TB isolation ward.

1.6 Significance of Study

The finding in this study is important to healthcare workers (HCWs) and TB patients. Preventing the nosocomial transmission of TB by centralised mechanical ventilation system for the TB isolation ward in Hospital Sultanah Aminah Johor Bahru, Johor, Malaysia is the sole purpose of this study. Thus a new healthcare setting layout in healthy indoor air environment is developed as follows:

- (i) Prevention person in high risk factors are divided into three categories, Persons who have been recently infected with TB bacteria, Persons with medical conditions that weaken the immune system and HCWs that work at TB Isolation ward.
- (ii) Benchmark the design to make a good design based on mock up centralised ventilation system.

- (iii) Selected TB isolation room has an optimum single bed layout that follows the requirements and specifications of Malaysia Uniform Building By-Laws 1984.
- (iv) Rationale mock up in ventilation system can get data and analysis for future layout.
- (v) Potential benefits of ventilation system can manage air flow, Air Change per Hour (ACH) and direction consistent level.
- (vi) Overall impact to prevent the nosocomial transmission of TB.

1.7 Novelty of Study

The Novelty of Study can be illustrated as follows:

- (i) Prototype to provide the functionality of centralised ventilation system and enables testing of the design.
- (ii) Designed can use prototype as single bed isolation room.
- (iii) Full-size model of a design, demonstration, evaluation, and promotion.
- (iv) Mock up TB Isolation room in order to experience a solution in real life.
- (v) The use of environmental and engineering controls solutions for preventing nosocomial transmission of TB in a hospital ward.
- (vi) Ventilation improve ACH to the added consistent level.
- (vii) Ventilation system provides fresh air force downward to exhaust out the stale air.
- (viii) Risk reduction of inhalation of pathogens and the reduction of incidence of TB disease transfer TB airborne with centralised mechanical ventilation system were produced in TB isolation ward.

1.8 Summary of Introduction

This whole chapter outlines the introduction to the problem and justifies the need to conduct this study. It states the aim, objectives, scopes and the adopted methodology. Furthermore it also elaborates the significance of the findings. The output of this study is the design and installation of centralised ventilation system as mock up TB Isolation Room . It provides a useful mean to healthcare workers to work at TB Isolation Ward. Moreover this mock up was developed based on our local working environment. This study hopefully enables the promotion of future isolation healthcare setting.

REFERENCES

- Air Infiltration and Ventilation Glossary. (1992). Technical Note AIVC 36. Bracknell, England: International Energy Agency, Air Infiltration Centre
- American Thoracic Society, ATS/CDC (2000). Targeted Tuberculin Testing and Treatment of Latent TB Infection. *MMWR* 2000; 49 (No. RR-6).
- American Thoracic Society, ATS/CDC (2003). Treatment of Tuberculosis. *MMWR* 2003; 49 (No.RR-11).
- ANSI/ASHRAE Standard 62.1-2010. (2010). Ventilation for Acceptable Indoor Air Quality. ISSN 1041-2336. American Society of Heating, Refrigerating, and Air-Conditioning Engineers, Inc., Atlanta.
- Argyrous, G, (2005). Statistics for Research: With a Guide to SPSS. London: SAGE. ISBN 1-4129-1948-7
- Bates J.H. and Stead W.W. (1993). The History of Tuberculosis as a Global Epidemic. *Med Clin North Am* 1993; 77: 1205-17.
- Behr, M.A., Warren, S.A., Salamon, H. (1999). "Transmission of from Patients Smear-negative for Acid-fast Bacilli". *Lancet* 353 (9151): 444–9.
- Carr, J.H. (2008). Centers for Disease Control and Prevention., <http://phil.cdc.gov/phil/details.asp?pid=9997>
- Centers for Disease Control and Prevention, (1995). Essential components of a tuberculosis prevention and control program. *MMWR* 1995; 44 (RR-11):1-16.
- Centers for Disease Control and Prevention, (1997). Guideline for Preventing the Transmission of Mycobacterium tuberculosis in Health-Care Facilities, 1994. *MMWR* 1994; 43(RR13);1-132.
- Centers for Disease Control and Prevention, (2000). Division of Tuberculosis Elimination. *Core Curriculum on Tuberculosis: What the Clinician Should Know*. 4th edition (2000). Updated August 2003.

- Centers for Disease Control and Prevention, (2003). Guidelines for Environmental Infection Control in Health-Care Facilities (2003), *MMWR* 2003; 52(RR-10): 1-42
- Centers for Disease Control and Prevention, (2005). Guidelines for Preventing the Transmission of Mycobacterium Tuberculosis in Health-care Settings, 2005. *MMWR* 2005; 54 (No.RR-17).
- Centers for Disease Control and Prevention, (2009). Questions and Answers about Tuberculosis 2009.
- Cermak R. and Melikov, A.K. (2006). Air quality and thermal comfort in an office with underfloor, mixing and displacement ventilation, *International Journal of Ventilation* 5 (3) (2006), p. 5.
- Cole, E. and Cook, C. (1998). "Characterization of Infectious Aerosols In Healthcare Facilities: An Aid To Effective Engineering Controls and Preventive Strategies". *Am J Infect Control* 26 (4): 453–64.
- Curry, F.J. (2007). Tuberculosis Infection Control: A Practical Manual for Preventing TB. National Tuberculosis Center.
- Daniel, T.M. (2006). The History of Tuberculosis. *Respiratory Medicine*, 2006. 100 (11): p. 1862-1870.
- Denés, T., Abadie, M., Limam, K. and Allard, F. (2006). Experimental Research of fine particle deposition in rooms, *Proceedings: Healthy Buildings* (2006), pp. 469–474.
- Department of Occupational Safety and Health, Ministry of Human Resources, Malaysia Industry Code of Practice on Indoor Air Quality. JKKP DP(S) 127/379/4-39. 2010
- Duchene, A.S., Lakey, J.R.A. and Repacholl M.H. (1991). IRPA Guidelines on Protection against Non ionizing Radiation. New York: Pergamon Press.
- Dugdale, D.C. (2009). A.D.A.M., Inc. is accredited by URAC, also known as the American Accreditation HealthCare Commission (www.urac.org)
- Escombe, A.R, Oeser, C.C., Gilman, R.H., Navincopa, M., Ticona, E., Pan, W., Martínez, C., Chacaltana, J., Rodríguez, R., Moore, D.A., Friedland, J.S., Evans, C.A. (2007). Natural Ventilation for The Prevention of Airborne Contagion, *PLoS Med.* 2007, 4(2):e68, Department of Infectious Diseases & Immunity, Imperial College London, London, United Kingdom.

- Etkind, S.C. (1993). The Role of the Public Health Department In Tuberculosis Control. *Med Clin North Am* ; 77:1303-1314.
- Häggström, M. (2009). http://en.wikipedia.org/wiki/File:Tuberculosis_symptoms.
- Harvey, Greg (2006). *Excel 2007 For Dummies*. Wiley. ISBN 0-470-03737-7.
- Gatley, D. P. (2002). *Understanding Psychrometrics*. Atlanta: American Society of Heating, Refrigerating and Air-conditioning Engineers.
- Goldwater, Eva (2008). *"Using Excel for Statistical Data Analysis — Caveats"*. University of Massachusetts School of Public Health. Retrieved November 10, 2008.
- Griffith, D. and Kerr, C. (1996). Tuberculosis: disease of the past, disease of the present. *J Perianesth Nurs* 11 (4): 240–5.
- Gruft, H., Clark, M.E., and Osterhout, M. (1967). Preservation of Mycobacterial Cultures. *Applied Microbiology* Vol. 16, No. 2.
- Heiselberg P.K. (ed.) (2002). Principles of Hybrid Ventilation. *International Energy Agency Annex 35 Final Report*, Department of Building Technology and Structural Engineering, Aalborg University, Denmark.
- Indoor Environment Quality (2004). Department of Building Services Engineering of Hong Kong Polytechnic University (2004).
- Kowalski, W., Bahnfleth, W.P. and Whittam, T.S. (1999). Filtration of Airborne Microorganisms: Modeling and Prediction, *ASHRAE Transactions*, Vol. 105, Part 2.
- Kowalski, W. (2009). *Ultraviolet Germicidal Irradiation Handbook*, DOI 10.1007/978-3-642-01999-9_1, Springer-Verlag Berlin Heidelberg 2009.
- Law of Malaysia, Uniform Building By-Laws 1984, Malaysia.1996
- Levesque, R. (2007). *SPSS Programming and Data Management: A Guide for SPSS and SAS Users* (4th ed.). Chicago, Illinois: SPSS Inc. ISBN 1-56827-390-8
- Majid, M.Z.A. (1997). *Non-Excusable Delays in Construction*. Ph.D. Thesis. University Loughborough, Leicestershire, UK, 1997
- Mayo Clinic (2006). Causes of Tuberculosis.
<http://www.mayoclinic.com/health/tuberculosis/DS00372/DSECTION=3>.
Retrieved 19 October 2009
- Md Rajuna Bin Ahmad Shakri, Rozana Binti Zakaria, and Badrul Hisham Bin Abd Samad (2011). Determining Relationship Between Physical Healthcare Settings and Mycobacterium Tuberculosis, *Applied Mechanics and Materials*.

- AMM Vols. 90-93 (2011) pp 2460-2465, Trans Tech Publications, Switzerland. doi:10.4028/www.scientific.net/AMM.90-93.2460.
- Md Rajuna Ahmad Shakri, Rozana Zakaria, Badrul Hisham Abd Samad, Khairulzan Yahya, Rosli Mohamad Zin, Mushairry Mustaffar, Muhd Zaimi Abd Majid and Noor Aliza Md Tarekh (2011). Healthy Indoor Air Environment for Preventing Nosocomial Transmission of *Mycobacterium Tuberculosis* in Sustainable Hospital Building Design., Malaysian Journal of Civil Engineering. MJCE Vol. 23(2) (2011) pp 80-91. Faculty of Civil Engineering, Universiti Teknologi Malaysia.
- Md Rajuna Bin Ahmad Shakri, Rozana Binti Zakaria, Khairulzan Bin Yahya, Badrul Hisham Bin Abd Samad and Noor Aliza Binti Md Tarekh (2012). The Sources and Factors of Tuberculosis Transmission at Hospital for Sustainable Indoor Air. International Journal of Environmental Protection. IJEP Vol. 2 No. 3 2012 Pp. 29-32. www.ij-ep.org. World Academic Publishing
- Melikov, A.K. (2004). Personalized ventilation, *Indoor Air* 14 (Suppl. 7) (2004), pp. 157–167.
- Ministry of Health Malaysia (2009). Annual Report of TB Registry 2007
- Ministry of Health Malaysia (2014), Health Fact 2014, Health Informatics Centre, Planning and Development Division Ministry of Health Malaysia, p.17
- Mundt (2001). Non-buoyant Pollutant Sources and Particles In Displacement Ventilation. *Building and Environment* 36 (2001), pp. 829–836.
- National Tuberculosis Controllers Association, National TB Nursing Consultant Coalition (1997). Tuberculosis nursing: a comprehensive guide to patient care. Atlanta, GA: *National Tuberculosis Controllers Association and National Tuberculosis Nursing Consultant Coalition*: 69-84
- Nicas, M. Nazaroff, W.W. and Hubbard, A. (2005). Toward Understanding the Risk of Secondary Airborne Infection: Emission of Respirable Pathogens. *Journal of Occupational and Environmental Hygiene* 2 (2005), pp. 143–154.
- Olesen, B. W. and Brager, G.S. (2004). A Better Way to Predict Comfort: The New ASHRAE Standard 55-2004. *ASHRAE Journal*, August.2004
- OSHA, Occupational Safety and Health Act, (1999). OSHA Regulations Respiratory Protection (Standards – 29 CFR 1910.134) - *Respirators*, Occupational Safety and Health Administration, Washington, DC.

- Otsuka Pharmaceutical Development and Commercialization (OPDC) (2014). Mycobacteriology Laboratory Manual 2014 Global Laboratory Initiative Advancing TB Diagnosis First Edition. 25-29.
- Porteous, A. (1992). Dictionary of environmental science and technology. New York: John Wiley & Sons.
- Qian, H., Li, Y., Nielsen, P.V., Hyldgaard, C.E., Wong, T.W. and Chwang, A.T.Y. (2006). Dispersion of exhaled droplet nuclei in a two-bed hospital ward with three different ventilation systems, *Indoor Air* 16 (2006), pp. 111–128.
- Sehulster, L., Chinn, R.Y. (2003). Guidelines for Environmental Infection Control in Health-Care Facilities. Recommendations of Centers for Disease Control and Prevention and the Healthcare Infection Control Practices Advisory Committee (HICPAC). MMWR Recomm Rep. 2003 Jun 6; 52(RR-10): 1-42.
- Siegel, J.D., Rhinehart, E., Jackson, M., Chiarello, L. (2007). Guideline for Isolation Precautions: Preventing Transmission of Infectious Agents in Healthcare Settings. 2007. Healthcare Infection Control Practices Advisory Committee.
- Simone, P.M. and Fujiwara, P.I. (1999). Role of the Health Department: Legal and Public Health Implications. In: Schlossberg D, editor. *Tuberculosis and non tuberculous mycobacterial infections*, 4th edition. Philadelphia: W.B. Saunders:130-139.
- Spalding, E.H. (1968). Chemical disinfection of medical and surgical materials. In: Lawrence CA and Block SS, eds. *Disinfection, sterilization and preservation*. Philadelphia, Lea & Febiger, 517-531.
- Tang, J.W., et al. (2006), Factors involved in the aerosol transmission of infection and control of ventilation in healthcare premises. *Journal of Hospital Infection*, 64(2): p. 100-114 .
- Thoen, C. Lobue, P. de Kantor I. (2006). The importance of *Mycobacterium bovis* as a zoonosis". *Vet. Microbiol.* 112 (2-4): 339–45.
doi:10.1016/j.vetmic.2005.11.047. PMID 16387455.
- Traylor, Mark (October 1983). "Ordinal and interval scaling". *Journal of the Market Research Society* **25** (4): 297–303.
- Trochim, William M. (October 20, 2006). "*Likert Scaling*". Research Methods Knowledge Base, 2nd Edition. Retrieved April 30, 2009.
- Uvarov, E. B., Chapman, D. R., and Isaacs, A. (1968). A dictionary of science. London: Penguin Reference Books.

- Vadrot, C., Bex, V., Mouilleseaux, A., Squinazi, F. and Darbord J.-C. (2004). Detection of *Mycobacterium tuberculosis* complex by PCR in hospital air samples. *Journal of Hospital Infection*, JHI Volume 58, Issue 4, December 2004, Pages 262–267. doi:10.1016/j.jhin.2004.04.026
- Wan, G.H. Lu, S.C. and Tsai, Y.H. (2004). Polymerase Chain Reaction Used For the Detection of Airborne *Mycobacterium Tuberculosis* in Healthcare Settings. *American Journal of Infection Control*. AJIC Volume 32, Issue 1, February 2004, Pages 17–22
- Wan, M.P. and Chao, C.Y.H. (2005). Effect of Changing the Air Distribution System on the Dispersion of Droplet Phase Aerosols in an Enclosure. *Proceedings: Indoor Air* (2005), pp. 2696–2700.
- Wang, L.K., Hung, Y.T. and Shammass, N.K. (2010). Advanced Physicochemical Treatment Processes, *Handbook of Environmental Engineering*, Volume 4, The Humana Press Inc., Totowa, NJ
- Weinstein, J.W., Hierholzer, W.J. and Garner, J.S. (1997). Isolation Precautions in Hospitals. In: Bennett JV and Brachman PS. *Hospital infection*. 4th ed. Philadelphia, Lippincott Williams and Wilkins, 1997 : 189-199.
- World Health Organization (2004). Regional Office for South-East Asia and Regional Office for Western Pacific, (2004). Practical guidelines for infection control in healthcare facilities, SEARO Regional Publication No.41.
- World Health Organization, (2013). Global tuberculosis control: a short update to the 2013 report. Geneva, World Health Organization/HTM/TB/2009.426 p.4
- World Health Organization, (2014). Global tuberculosis report 2014, World Health Organization/htm/TB/2014.08 p.34
- Xie, X. and Li, Y. (2006). How far respiratory droplets move in indoor environments?, *Proceedings Healthy Buildings*, pp. 309–314.
- Yang, S., Lee, G.W.M., Chen, C.M., Wu, C.C. and Yu, K.P. (2007). The Size and Concentration of Droplets Generated by Coughing in Human Subjects. *Journal of Aerosol Medicine* 20 (4), pp. 484–494.